

Power Flow Management of Grid Connected Wind Generation System with Power Quality Improvement Features

Abstract-

In recent years with the excessive consumption of electrical energy, the Contradiction between generation and demand, the irrational structure of World's energy as well as the environmental pollution have become progressively more evident. It has become crucial for ecological development to reduce the consumption of conventional energy and to enhance the development and utilization of renewable energy. Wind energy and Solar are unlimited supply of renewable energy. and it has no pollution. But this concept suffer from the power quality issues from grid and generator side, this paper presents a control strategy for achieving maximum benefits from these grid-interfacing inverter when installed in 3-phase 4-wire distribution systems. The inverter can be controlled to perform as a multi-function device by incorporating active power filter functionality. The inverter can thus be utilized as: 1) power converter to inject power generated from RES to the grid and 2) shunt APF (Active Power Filter) to compensate current unbalance, load current harmonics, load reactive power demand and load neutral current. All of these functions may be accomplished either individually or simultaneously. With such a control, the combination of grid-interfacing inverter and the 3-phase 4-wire linear/non-linear unbalanced load at point of common coupling appears as balanced linear load to the grid. The design and implementation of Wind turbine generation system studied, and simulated in MATLAB/SIMULINK.

Keywords: Power Quality, Harmonics, Reactive Power, DSTATCOM

1. INTRODUCTION

Now a day's power demand is increasing at a faster rate than power generation. Hence the utilities are concentrated on power generation in order to meet the increased demand. Out of total energy demand, 75% load is supplied from fossil fuels. Because of this, there are so many problems related to environment such as air pollution, green house effect, lessening fossil fuels. Hence it is necessary to check for another alternative for power generation i.e. renewable energy sources. From past ten years, many countries have concentrated on these renewable energy sources for power generation.

Presently, the government also motivating the people towards the use of renewable energy sources. Accelerated the renewable energy sector growth. Injecting wind power into the power system grid effects power quality problems such as reactive power compensation, voltage regulation, harmonics produced in the grid. We know reactive problems may come due to non-linear loads balanced and unbalanced loads some kind of power electronic devices such as arc lamps welding machines etc. this all are switching actions harmonics will present in the system so that complete grid effects and also it effects on source side.

Generally, current controlled voltage source inverters are used to interface the intermittent RES in distributed system. Recently, a few control strategies for grid connected inverters incorporating PQ solution have been proposed. In an inverter operates as active inductor at a certain frequency to absorb the harmonic current. But exact calculation of network inductance in real-time is difficult and may deteriorate the control performance. A similar approach in which a shunt active filter acts as active conductance to damp out the harmonics in distribution network is proposed in a control strategy for renewable interfacing inverter based on theory is proposed. In this strategy both load and inverter current sensing is required to compensate the load current harmonics. The non-linear load current harmonics may result in voltage harmonics and can create a serious PQ problem in the power system network. Active power filters (APF) are extensively used to compensate the load current harmonics and load unbalance at distribution level. Here, the main idea is the maximum utilization of inverter rating which is most of the time underutilized due to intermittent nature of RES. It is shown in this paper that the grid-interfacing inverter can effectively be utilized to perform following important functions: 1) transfer of active power harvested from the renewable resources (wind, solar, etc.); 2) load reactive power demand support; 3) current harmonics compensation at PCC; and 4) current unbalance and neutral current compensation in case of 3-phase 4-wire system.

Moreover, with adequate control of grid-interfacing inverter, all the four objectives can be accomplished either individually or simultaneously. The PQ constraints at the PCC can therefore be strictly maintained within the utility standards without additional hardware cost.

2. PROBLEM FORMULATION




Fig.1. Block diagram of grid connected wind generation system at distribution level

The proposed system consists of RES (Renewable Energy Source) connected to the intermediate circuit of an inverter network-interface as shown in Fig. 1. The voltage source inverter is a key element of a system of DG and interconnecting the source of renewable energy to the grid and provides power generated. The RES can be a DC source or an AC source coupled to rectifier dc-link. Usually energy sources fuel cell and photovoltaic energy generated in lower variable voltage dc, while variable-speed wind turbines generate power in variable AC voltage. Therefore, the energy generated from these renewable power conditioning needs (dc / dc or ac / dc) before connecting the dc-link [6] - [8]. The DC-capacitor-RES decouples the network and also allows independent control of converters on both sides of dc-link

A. Wind Energy Generating System.

In this configuration, the production of wind energy is based on topologies constant speed with ground control turbine. The induction generator is used in the proposed scheme because of its simplicity, it does not require a separate field circuit, it can accept constant and variable loads, and the natural protection against short circuit. The

power available from the wind energy system is presented as:

$$P_{wind} = \frac{1}{2} \rho A V_{wind}^3 \quad (1)$$

It is not possible to extract all kinetic energy of wind. Thus extracts a fraction of the power called power coefficient 'Cp' of the wind turbine, and is given by

$$P_{mech} = C_p P_{wind} \quad (2)$$

The mechanical power produced by wind turbine is given by

$$P_{mech} = \frac{1}{2} \pi R^2 V_{wind}^3 C_p \quad (3)$$

B. DC-Link Voltage and Power Control Operation

Due to the intermittent nature of RES, the generated power is of variable nature. The dc-link plays an important role in transferring this variable power from renewable energy source to the grid. RES are represented as current sources connected to the dc-link of a grid-interfacing inverter. The current injected by renewable into dc-link at voltage level can be given as:

$$I_{dc1} = \frac{P_{RES}}{V_{dc}} \quad (4)$$




Fig.2. DC-Link Equivalent Diagram.

The current flow on the other side of dc-link can be represented as,

$$I_{dc2} = \frac{P_{inv}}{V_{dc}} = \frac{P_G + P_{Loss}}{V_{dc}} \quad (5)$$

If inverter losses are negligible then $P_{RES} = P_G$.

3. Idq CONTROL TECHNIQUE

By using instantaneous active and reactive currents i_{d-q} control technique reference current can be obtained through the non linear load.

Calculations follow like the instantaneous power theory, but dq load currents are often obtained from equation (6) 2 stage transformations make known relation between the stationary and rotating system with active and reactive current methodology. The transformation angle ' θ ' is wise to all or any voltage harmonics and unbalanced voltages; as a result $d\theta/dt$ might not be constant.

The system d-q (d direct axis, q-quadrature axis) is set by the angle θ with respect to the α - β frame utilized in the p-q theory. The transformation from α - β - zero frame to d-q -0 frames is given by

$$\begin{bmatrix} i_0 \\ i_d \\ i_q \end{bmatrix} = \frac{1}{v_{\alpha\beta}} \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos\theta & \sin\theta \\ 0 & -\sin\theta & \cos\theta \end{bmatrix} \begin{bmatrix} i_0 \\ i_\alpha \\ i_\beta \end{bmatrix} \quad (6)$$

If the d axis is within the direction of the voltage space vector, since the zero-sequence part is invariant, the transformation is given by

$$\begin{bmatrix} i_d \\ i_q \end{bmatrix} = K \begin{bmatrix} i_\alpha \\ i_\beta \end{bmatrix} \quad (7)$$

$$K = \frac{1}{v_{\alpha\beta}} \begin{bmatrix} v_\alpha & v_\beta \\ -v_\beta & v_\alpha \end{bmatrix} \quad (8)$$

$$K = \frac{1}{\sqrt{v_\alpha^2 + v_\beta^2}} \begin{bmatrix} v_\alpha & v_\beta \\ -v_\beta & v_\alpha \end{bmatrix} \quad (9)$$

Where the transformation matrix K, satisfies $\|K\| = 1$ and $K^{-1} = K^T$

Each current component (I_d , I_q) has an average value or dc component and an oscillating value or ac component

$$\left. \begin{aligned} i_d &= \bar{i}_d + \tilde{i}_d \\ i_q &= \bar{i}_q + \tilde{i}_q \end{aligned} \right\} \quad (10)$$

The compensating strategy (for harmonic reduction and reactive power compensation) assumes that the supply should deliver the average of the direct-

axis element of the load current. The reference supply current can so be

$$i_{sdref} = \bar{i}_{Ld}; i_{sqref} = i_{s0ref} \quad (11)$$

In this methodology, the currents magnitude changes its axes and p-q formulation is simply performed on the instant active id and instant reactive Iq parts. If the d axis has constant direction because the voltage space vector v, then the zero-sequence element of current remains invariant. Therefore, the i_{d-q} methodology is also expressed as follows:

$$\begin{bmatrix} i_d \\ i_q \\ i_0 \end{bmatrix} = \frac{1}{v_{\alpha\beta}} \begin{bmatrix} v_\alpha & v_\beta & 0 \\ -v_\beta & v_\alpha & 0 \\ 0 & 0 & v_{\alpha\beta} \end{bmatrix} \begin{bmatrix} i_{L\alpha} \\ i_{L\beta} \\ i_{L0} \end{bmatrix} \quad (12)$$

In this strategy, the supply should deliver the constant term of the direct-axis of the load (for harmonic compensation and power issue correction). The reference supply current is going to be calculated as follows:

$$i_{sd} = \bar{i}_{Ld}; i_{sq} = i_{s0} = 0 \quad (13)$$

$$i_{Ld} = \frac{v_\alpha i_{L\alpha} + v_\beta i_{L\beta}}{v_{\alpha\beta}} = \frac{P_{L\alpha\beta}}{\sqrt{v_\alpha^2 + v_\beta^2}} \quad (14)$$

The dc component of the above equation will be

$$\bar{i}_{Ld} = \left(\frac{P_{L\alpha\beta}}{v_{\alpha\beta}} \right)_{dc} = \left(\frac{P_{L\alpha\beta}}{\sqrt{v_\alpha^2 + v_\beta^2}} \right)_{dc} \quad (15)$$

Where the subscript "dc" suggests that the mean value of the expression inside the parentheses. Since the reference supply current should to be sinusoidal and in phase with the voltage at the PCC (and hasn't any zero-sequence component), it'll be calculated (in α - β -0 coordinate) by multiplying the on top of equation by a unit vector within the direction of the PCC voltage space vector (excluding the zero sequence components):

$$i_{sref} = \bar{i}_{Ld} \frac{1}{v_{\alpha\beta}} \begin{bmatrix} v_\alpha \\ v_\beta \\ 0 \end{bmatrix} \quad (16)$$

$$\begin{bmatrix} i_{s\alpha ref} \\ i_{s\beta ref} \\ i_{s0 ref} \end{bmatrix} = \left(\frac{P_{L\alpha\beta}}{v_{\alpha\beta}} \right)_{dc} \frac{1}{v_{\alpha\beta}} \begin{bmatrix} v_{\alpha} \\ v_{\beta} \\ 0 \end{bmatrix} \quad (17)$$




Fig.3. Transformation and injection of harmonic current

4. MATLAB MODELEING AND SIMULATION RESULTS

The proposed control scheme is simulated by using MATLAB/SIMULINK in power system block set. The Simulation parameters used for the system is given in table 1.

Table:1 System parameters

S. No	System quantities	Parameters values
1	Source	3 phases, 11kv, 50Hz
2	Wind DC voltage	800Vdc, 1200Vref.
3	3 phase Δ/Y Winding transformer	11kv Δ/415v Y
4	Non-Linear Load	3phase, 4 Wire Diode Rectifier Circuit, L1=(R= 20Ω, L=20mH) L2=(R=20Ω, L=20mH) L3=(R= 20Ω, L=20mH)
5	Linear Load	3phase un balanced load L6=(R=6,L=20mH),L7=(R=15, L=20mH),L8=(R=8)

MATLAB simulation circuit consist of wind integrated grid system is shown in fig.4 it holds an unbalanced linear load and diode bridge rectifier for analyzing the unbalanced and harmonic problems. 132kV grid system is step down to 415V by using 3 phase Δ/Y winding transformer and the system specification are shown in table. The IGBT based three phase inverter is connected to grid. The generation of switching signals from reference current is simulated within hysteresis band of 0.08 for Bang-Bang current controller. The real power transfer from the batteries is also supported by the controller of this inverter. The three phase inverter injected current are shown in fig 6.




Fig 4: MATLAB/Simulink Model of proposed system.




Fig.5: Simulink model of wind turbine




Fig 6: Three phase wave forms of source current, Load current, inverter currents and source voltage




Fig 7: Simulated output wave forms of Source, load and Compensated active and re-active powers.




Fig 8: Power factor maintained unity when the STATCOM is acting from 0.6 sec.




Fig.9: Total Harmonics distortion of source current




Fig 10: Total Harmonics distortion of source currents.

Analysis from the results

The simulation work is done for 3 phase, four wire grid interface wind system using MATLAB/Simulink. A four-leg hysteresis controlled voltage source inverter is actively controlled to reach fair sinusoidal currents from nonlinear load and varying renewable generating conditions. Fig 6 shows grid voltage, grid currents, UN balanced load current and inverter currents. At $t=0$ s, the controlled inverter is not connecting to the system up to 0.6 s it follows the grid current profile is similar to the load current profile. At $t=0.6$ s, the controlled inverter is attached to the system. Right now the inverter start injects the current in such a way that the profile of grid current starts changing from unbalanced non linear to balanced sinusoidal current and Grid side neutral current becomes zero after $t=0.6$ s.

At $t=0.6$ s, the inverter starts injecting active power from RES. since the generated power is more than the demand the additional power is fed back to the grid. The more amount active power injection from renewable source to the grid is observed at $t=0.8$ s, this shows the magnitude of the inverter current is more. Treated load

demand is remains unchanged. At $t=0.92$ s, the active power injection from renewable source is reduced. Corresponding grid currents are shown in fig 6 Corresponding active and re-active power flows between the inverter, load and grid during increase and decrease of energy generation can be observed in fig. 7 Voltage across The DC-Link should be maintained constant at different conditions. From the results we conclude the grid-interfacing inverter can be efficiently used to balance the load reactive power at I_{dq} control strategy.

5. CONCLUSION

In the presented paper improve the power quality is the main objective for grid connected wind generation system for that choose as a interfacing inverter i.e grid interfacing inverter at PCC for 3-phase 4 wire system from the results it is observed that interfacing inverter works efficiently used for power controlling without effecting the normal operation. The inverter operates as both the functions draws or supplies the active and reactive power from RES to grid. And it is also used as APF when no generation from RES. The advantage of the proposed work is doesn't require additional equipment for improves the power quality. Due to unbalanced and non-linear load, the problems of current unbalance, current harmonics and load reactive power, are eliminated by controlling the inverter gate pulses.

For generating the gate pulses to the inverter I_{dq} (SRF)control theory control theory is presented. For nonlinear load it is observed that the source current is having THD of 24.12%. After compensation, by the results it is clearly observed the THD values are reduced to 1.97%, whereas the power Quality is improved.

REFERENCES

- [1] Improved active power filter performance for renewable power generation systems, IEEE TRANS ON POWER ELECTRONICS,VOL.29 NO.2,FEBRUARY 2014
- [2] Rejil C, Anzarim and Arun Kumar R Design And Simulation Of Three Phase Shunt Active Power Filter Using SRF Theory Advance in Electronic and Electric Engineering, Volume 3, Number 6 (2013).
- [3] A text book of wind and solar power system by Prof. Dr. Mukund R.Patel. Springer publications.
- [4] Grid interconnections of renewable energy source at the distribution level with power-quality improvement features IEEE TRANSON POWER DELIVERY, VOL.26, and NO.1.JANUARY 2011.
- [5] A STATCOM-Control Scheme for Grid Connected Wind Energy System for Power Quality Improvement, IEEE SYSTEM JOURNAL, VOL.4, NO.3, SEPTEMBER 2010
- [6] J. P. Pinto, R. Pregitzer, L. F. C. Monteiro, and J. L. Afonso, "3-phase 4-wire shunt active power filter with renewable energy interface," presented at the Conf. IEEE RNEWABLE ENERGY & POWER QUALITY, SEVILLE, SPAIN, 2007
- [7] J. H. R. Enslin and P. J. M. Heskes, "Harmonic interaction between a large number of distributed power inverters and the distribution network," *IEEE TRANS. POWER ELECTRON.*, VOL. 19, NO. 6, PP. 1586–1593, NOV. 2004
- [8] A hybrid passive filter configuration for VAR control and harmonic compensation, IEEE TRANS ON INDUSTRIAL ELECTRONICS, VOL.57, NO.7,JULY 2010
- [9] H. Akagi, Y. Kanazawa, and A. Nabae, "Instantaneous reactive power compensators comprising switching devices without energy storage components,"*IEEE Transactions on Industry Applications*, vol.IA-20, no.3, pp.625–630, May/Jun. 1984.
- [10] M.P. Kazmierkowski, and L. Malesani, "Current control techniques for three-phase voltage-source PWM converters a survey", *IEEE Trans. Ind. Elect.*, vol.45, no.5 pp.691–703, October 1998.
- [11] Gokulananda Sahu,Kamalakanta Mahapatra "Comparison of Control Strategies of DSTATCOM for Non-linear Load Compensation".
- [12] Franceschini, Lorenzani, E. Tassoni, C. Bellini, A Synchronous Reference Frame Grid Current Control for Single-Phase Photovoltaic Converters IEEE Transaction 2008.
- [13] C. Wessels, F. Gebhardt, and F. W. Fuchs, "Fault ride-through of a DFIG wind turbine using a dynamic voltage restorer during symmetrical and asymmetrical grid faults," *IEEE Trans. Power Electr.*, vol. 26, no. 3, pp. 807–815, Mar. 2011.



T.Suneel received his Bachelor degree in Electrical and Electronics Engineering from Gudlavalleru Engineering College, Gudlavalleru (INDIA) in 2007 and M.Tech in Power Electronics and Drives from VIGNAN Engineering College, JNTU University Kakinada, (INDIA) in 2009. He is currently working as an Assistant Professor in Electrical and Electronics Engineering Department at V.R.Siddhartha Engineering College Vijayawada, (INDIA). His research interests includes Power Electronics, Power Electronics Drives and Power Systems.



Giridhar Boyina received his Bachelor degree in Electrical and Electronics Engineering from V.R.Siddhartha Engineering College Vijayawada, (INDIA) in 2012 and Master of Science in Software Engineering from JNTU, Hyderabad (INDIA) in 2015. He is currently working in Trixon Tech Solutions Hyderabad, (INDIA). His research interests includes Power Systems, Power Electronics Drives and Software Engineering.



R.Dileep Kumar received his Bachelor degree in Electrical and Electronics Engineering from sri sunflower college of Engineering & technology. Lankapalli (INDIA) in 2012 and pursuing M.Tech in Power Systems Engineering at V.R.Siddhartha Engineering College Vijayawada, (INDIA)